



Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

STATE OF INDIANA)
) SS: ADMINISTRATIVE ORDER OF THE INDIANA
COUNTY OF MARION) STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – water in storage tank
Registration Number: M2-921263

IN THE MATTER OF THE OPERATION OF)
Circle K #44)
6743 East Washington Street)
Indianapolis, Indiana 46219)

TO: Circle K #44
6743 East Washington Street.
Indianapolis, Indiana 46219

EMERGENCY STOP-SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (87 octane) motor fuel, at the facility known as **Circle K #44**, located at **6743 East Washington Street Indianapolis, Indiana 46219**. This order is based upon the following:

Circle K #44 is a motor fuel outlet facility engaged in the sale of motor fuel to the public. On February 22, 2011 a Representative of the Division of Weights and Measures, Indiana State Department of Health, conducted an inspection of **Circle K#44** facility of the unleaded (87 octane) grade of gasoline. The results of Sar-gel paste test conducted on said motor fuel storage tanks reveals 3 inches of water in 87 unleaded storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of Unleaded (87 octane) Motor fuel from the fuel pumps dispensing at the facility known as **Circle K #44 6743 East Washington Street Indianapolis, Indiana 46219**.

This **ORDER** shall remain in effect until such time as the fuel has been upgraded in accordance with 410 IAC 12.1-2-3 (e) or has been disposed of in accordance with 410 IAC 12.1-2-3 (d).



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner


This **ORDER** is effective upon issuance.

If you wish to request a hearing on this **ORDER**, pursuant to IC 4-21-.5-4, you are required to forward a written request to the Indiana State Department of Health, at the office of Secretary, 2 North Meridian Street, Indianapolis, Indiana 46204 on or before **March 30, 2011.**

Dated at Indianapolis, Indiana this 22nd day of February 2011.

Respectfully submitted,

DIVISION OF WEIGHTS AND MEASURES,
MOTOR FUEL INSPECTION PROGRAM OF THE
INDIANA STATE DEPARTMENT OF HEALTH



Larry J. Stump, Director
Division of Weights and Measures,
Motor Fuel Inspection
lstump@isdh.in.gov
317-356-7078 ext.225

Received by: _____

Date: 2/22/2011



Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

STATE OF INDIANA)
) SS: ADMINISTRATIVE ORDER OF THE INDIANA
COUNTY OF MARION) STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – water in storage tank
Registration Number: L3-92271

IN THE MATTER OF THE OPERATION OF)
The Grocery Shoppe)
Marathon)
4535 N. Wozniak Rd.)
Michigan City, Indiana 46360)

TO: The Grocery Shoppe - Marathon
4535 N. Wozniak Rd.
Michigan City, Indiana 46360

EMERGENCY STOP-SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (93 octane) motor fuel, at the facility known as **The Grocery Shoppe (Marathon)**, located at 4535 N. Wozniak Rd. Michigan City, Indiana 46360. This order is based upon the following:

The Grocery Shoppe (Marathon) is a motor fuel outlet facility engaged in the sale of motor fuel to the public.

On February 22, 2011 a Representative of the Division of Weights and Measures, Indiana State Department of Health, conducted an inspection of **The Grocery Shoppe (Marathon)** facility of the unleaded (93 octane) grade of gasoline. The results of Sar-gel paste test conducted on said motor fuel storage tanks reveals 3 inches of water in Premium storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of Unleaded (93 octane) Motor fuel from the fuel pumps dispensing at the facility known as **The Grocery Shoppe (Marathon) 4535 N. Wozniak Rd. Michigan City, Indiana 46360.**

This **ORDER** shall remain in effect until such time as the fuel has been upgraded in accordance with 410 IAC 12.1-2-3 (e) or has been disposed of in accordance with 410 IAC 12.1-2-3 (d).



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

This **ORDER** is effective upon issuance.

If you wish to request a hearing on this **ORDER**, pursuant to IC 4-21-.5-4, you are required to forward a written request to the Indiana State Department of Health, at the office of Secretary, 2 North Meridian Street, Indianapolis, Indiana 46204 on or before **March 30, 2011.**

Dated at Indianapolis, Indiana this 22nd day of February 2011.

Respectfully submitted,

DIVISION OF WEIGHTS AND MEASURES,
MOTOR FUEL INSPECTION PROGRAM OF THE
INDIANA STATE DEPARTMENT OF HEALTH

Larry J. Stump, Director
Division of Weights and Measures,
Motor Fuel Inspection
lstump@isdh.in.gov
317-356-7078 ext.225

Received by: _____

Date: 2/22/2011



**Indiana State
Department of Health**
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

STATE OF INDIANA)
) SS: ADMINISTRATIVE ORDER OF THE INDIANA
COUNTY OF MARION) STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – water in storage tank
Registration Number: P7-20500

IN THE MATTER OF THE OPERATION OF)
Clark)
404 East Washington Street)
Greencastle, Indiana 46135)

TO: Clark
404 East Washington Street.
Greencastle, Indiana 46135

EMERGENCY STOP-SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (87 octane) motor fuel, at the facility known as **Clark**, located at **404 East Washington Street, Greencastle, Indiana 46135**. This order is based upon the following:

The **Clark** station is a motor fuel outlet facility engaged in the sale of motor fuel to the public. On February 15, 2011 a Representative of the Division of Weights and Measures, Indiana State Department of Health, conducted an inspection of the **Clark** facility of the unleaded (87 octane) grade. The result of Sar-gel water test conducted on said motor fuel storage tank revealed the presence of water in the underground storage tank. A total of 5 inches of water in (87) unleaded storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of Unleaded (87 octane) Motor fuel from the fuel pumps dispensing at the facility known as **Clark, 404 East Washington Street, Greencastle, Indiana 46135**

This **ORDER** shall remain in effect until such time as the fuel has been upgraded in accordance with 410 IAC 12.1-2-3 (e) or has been disposed of in accordance with 410 IAC 12.1-2-3 (d).



Indiana State
Department of Health
An Equal Opportunity Employer

Mitchell E. Daniels, Jr.
Governor

Gregory N. Larkin, M.D., F.A.A.F.P.
State Health Commissioner

This **ORDER** is effective upon issuance.

If you wish to request a hearing on this **ORDER**, pursuant to IC 4-21-.5-4, you are required to forward a written request to the Indiana State Department of Health, at the office of Secretary, 2 North Meridian Street, Indianapolis, Indiana 46204 on or before **March 23, 2011.**

Dated at Indianapolis, Indiana this 16th day of February 2011.

Respectfully submitted,

DIVISION OF WEIGHTS AND MEASURES,
MOTOR FUEL INSPECTION PROGRAM OF THE
INDIANA STATE DEPARTMENT OF HEALTH

Larry J. Stump, Director
Division of Weights and Measures,
Motor Fuel Inspection
lstump@isdh.in.gov
317-356-7078 ext.225

Received by:

Date: 2/16/2011